



广 微 测
Gmicro Testing

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

Report №.

2020FM28417R01E

Name of Sample

Air Purifying Disinfector

Applicant

Qierling (Beijing) Health Technology Co., Ltd.

Test Type

Entrustment Test



Address: Building 66, No.100 Central Xian Lie Road, Guangzhou, China

Postcode: 510070

Tel: +86 20 87137666

Fax : +86 20 87137668

Website : www.gddcm.com




GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS



Report №.:2020FM28417R01E Verification Code: 24651703

Name of Sample	Air Purifiering Disinfector	Test Type	Entrustment Test
Applicant	Qierling (Beijing) Health Technology Co., Ltd.	Address	No 101-42/101-43 (Dongsheng district), 9th Floor, No 1 Building, No 8th, Heiquan Road, Haidian District, Beijing City.
Sample Source	Submitted for Testing by the Applicant	Sample Quantity	One Sample Submitted
Spec and Lot № of Sample	DS-X400N	State and Characteristic	Machine
Sample Received Date	2020-10-12	Test Completion Date	2020-10-23
Test Standard and Method	Refer to GB 21551.3-2010 Appendix A		
Item Tested	Air virus elimination effect		
Test Conclusion	<p>The test data of the sample(s) is attached to the page(s) of this report.</p> <p style="text-align: right;">Issue Date: 2020-12-07 (Official Seal)</p>		
Remarks	<p>Main inspection model: DS-X400N and models: DS-X400W, DS-P400 are the same kind of products. (Communication module is different, others are the same) provided by the applicant)</p>		



Editor: Qiuwanchun

Verifier: Li Sujuan

Approver: Xie Xiaobao



GUANGDONG DETECTION CENTER OF MICROBIOLOGY

ANALYSIS AND TEST RESULT

Report No.: 2020FM28417R01E

Virus and host cell	Action Time	Serial Number	Air virus content (TCID ₅₀ /m ³)	Removal rate (%)
Infectious bronchitis Virus Host cell: SPF embryonated hen's eggs	0 (CK)	1	5.47×10 ⁶	
		2	5.47×10 ⁶	
		3	1.73×10 ⁶	
	1h	1	<97.3	>99.99
		2	<97.3	>99.99
		3	<97.3	>99.99

Note: The natural decay of the microorganisms in the air has been eliminated.

Photo of the sample:



(Blank below)



Remarks	The experiment was performed in a 30m ³ test cabin.
---------	--



Report №.: 2020FM28417R01E

Notice Items

1. The Test report is invalid if not affixed with Authorized Stamp of Test and Paging Seal.
2. The Test report is invalid without signature of verifier and approver.
3. The Test report is invalid if being supplemented, deleted or altered.
4. Without prior written permission, the report cannot be reproduced, except in full.
5. Unless otherwise stated, the results shown in this test report refer only to the sample(s) submitted.
6. Any dispute of the report must be raised to the testing body within 15 days after the report is received, exceeding which the dispute will not be accepted.
7. For the tested sample(s) submitted by the applicant, the sample information in the test report is provided by the applicant and the laboratory is not responsible for its authenticity.
8. This test report is for reference only to the applicant and does not have a proof of effect for others.

